



(A STATE GOVT. UNDERTAKING, CIN U40101HP2006SGC030591) Office of the Sr. Manager (Procurement & Contracts) Sainj Hydro-Electric Project (100 MW) Sarabai (Bhuntar), Distt.-Kullu, (HP)-175125

Website: www.hppcl.inE-mail:smlarji.e@gmail.comFax &Phone No: 01902 265191

SHORT TERM NOTICE INVITING QUOTATIONS

Sealed quotations are hereby invited by the undersigned on behalf of Himachal Pradesh Power Corporation Limited for Power House site of Sainj HEP, HPPCL, Matla, Distt-Kullu, (HP)-175134 from the reputed Firm/Agency OR Govt. Contractors/Supplier registered with HPPCL, HPSEBL, HPPWD, CPWD, MSME and other State or Central Govt. Organization subject to below mentioned terms & conditions. The quotations should reach in the office of undersigned on or before 17/06/2025 at 11:00 AM and shall be opened on same day at 12:15 PM by the constituted tender evaluation committee in presence of bidders or their authorized representatives who may wish to be present at that time.

| Sr. No. | Description item: | Unit | Qty. | Rate exclusive of | Total Amount exclusive of | Rate of applicable |
|------------|--|------|------|----------------------|---------------------------|--------------------|
| 1 | Repairing, rewinding & overhauling of 50 HP, 3-Phase 415V motor with replacement of bearing etc. | No. | 01 | GST (in Rs.) | GST (in Rs.) | GST in %age |
| 2 | Repairing of 1 HP 1-Phase, make: Crompton, mini self- priming Tullu pump with replacement of bearing etc. | No. | 04 | | | |
| | Total amount quoted (in Rs.) exclusive of GST= | | | | | |

Terms and Conditions:-

- Rates shall be F.O.R. inclusive collect and return back the rewind motor at E&M Store of Sainj Hydro-Electric Project, Matla near Suind, Sub-Tehsil-Sainj, Distt-Kullu, (HP)-175134 and all other charges whatsoever and shall be FIRM. 2.
- The evaluation of quotations shall be done without considering GST. The GST shall be paid extra as per actual applicability at the time of invoicing.
- The price bid along with all relevant documents should be sealed together in an envelope 3. super scribed with Name of work & Notice Inviting Quotation Ref. No: and Tender (NIQ) Opening date along with the name and address of the bidder clearly mentioned on the envelope. The envelope should be sent at the address of undersigned. 4.
- HPPCL shall not be responsible for delay / failure in submission of the quotations.
- The rates quoted by the bidders shall be valid for 90 days from the due date of opening of 5. 6.
- The quotations received after due date & time shall not be accepted under any circumstances. 7.
- In case the scheduled date of opening of quotations happens to be a holiday, the quotations shall be opened on next working day. 8.
- HPPCL reserve its right to reject any one or all the quotations without assigning any reason 9.
- The rates quoted for above should not contain any interlineations or overwriting. In case there is a discrepancy between the rate of words and figures, the rate in words shall prevail. 10.
- The quantity can be increased or decreased at the time of issuing of supply order.
- The quotations should be strictly as per the above specified price schedule and terms & conditions of HPPCL and quotations with any deviation in the same shall be rejected.
- Detailed scope of job work: 12.

Regd. office: Himfed Building, Near BCS, New Shimla, HP-171009.

Pg 01 of 03

HIMACHAL PRADESH POWER CORPORATION LIMITED



(A STATE GOVT. UNDERTAKING, CIN U40101HP2006SGC030591) Office of the Sr. Manager (Procurement & Contracts)

Sainj Hydro-Electric Project (100 MW)

Sarabai (Bhuntar), Distt.-Kullu, (HP)-175125 Website: www.hppcl.inE-mail:smlarji.e@gmail.comFax &Phone No: 01902 265191

For the rewinding of motors, contractor is responsible to collect and return back the i. motors to E&M Store near Power House site of Sainj HEP.

The bidder should have necessary workshop rewinding and testing facilities and ii. competent skill manpower to carry out the job satisfactorily. iii.

Dismantling of the complete motor at the contractor works, taking-out of all the damaged/ burnt coils along with the remaining coils from the stator core.

Cleaning of stator core slots properly/ hot spot testing of bare stator core. iv.

Complete cleaning & thorough checking of other components. V. vi.

The standard material like B.I.C. Copper wire, Fiberglass sleeve, PVC garware paper etc. for motor re-winding work.

Rewinding of the stator (as per the original exact size, shape and grade) with new super vii. enamelled copper conductor/wire of correct gauges, nos. of turns, weight and of reputed make conforming to IS-4800 with latest amendment with "F/H" class insulation on the slots, joints & complete set of coils an over hand portion. viii.

Applying insulation varnish after pre-heating and baking the re-wound stator in temperature controlled oven.

Providing and replacement of defective terminal plate/epoxy insulator with proper ix. connection studs/thimbles, delta strips etc. The studs shall be brazed with winding leads by silver brazing rods. X.

Rebuilding/providing & fixing of under size sleeve, locking and tagging with suitable locking arrangement, machining and polishing of rebuild/sleeves portion as per bearing

Dynamic balancing of motor with fan impeller assembly. Replacement of damaged xi. bearing with new set of bearing (SKF/FAG).

The work will be completed as per direction of Engineer-in-Charge. Material required xii. for successful completion of work will be in the scope of contractor. No extra payment in any account will be made. xiii.

As and when required, HPPCL Engineer will inspect the repair job work of motors at the contractor workshop.

The motor shall be assembled with fresh lubrication to the bearing & IR shall be taken xiv. in the presence of authorized Engineer of HPPCL. XV.

At the time of delivery of equipment after repair/ rewinding, the contractor shall furnish all the information like IR value of Megger test, resistance per phase, no-load & full load losses, Dynamic balancing of motor, bearing test report and other data related to the repaired motors. xvi.

The contractor will give 6 months guarantee for the motor re-winding work. In case of any failure within 6 months, contractor will do re-winding work free of cost.

The job order shall be completed within Two (02) weeks after handing over the motors for repairing, rewinding & overhauling to the contractor at E&M store of Sainj HEP. 14.

The material used for motors repairing, rewinding & overhauling should be branded, entirely new, of the best quality to the entire satisfaction of HPPCL. In case the material is of bad / poor quality, defective, expired date and not as per specification then HPPCL reserve the right to reject the entire lot without any financial implication on part of HPPCL.

No work shall be eligible for payment till the same is accepted as satisfactory/certify for payment by HPPCL Engineer, who will authorized by Engineer-in-Charge of job work.

The 80% payment shall be made after the completion of work upon the submission of verified Test reports/ completion certificate and issued by the Engineer-in-Charge, Tax Invoice along with other documents, if applicable. 17.

The balance 20% payment shall be made after the completion of 6 months guarantee period or any extension thereto.

Regd. office: Himfed Building, Near BCS, New Shimla, HP-171009.

Pg 02 gl 03

HIMACHAL PRADESH POWER CORPORATION LIMITED



(A STATE GOVT. UNDERTAKING, CIN U40101HP2006SGC030591) Office of the Sr. Manager (Procurement & Contracts) Sainj Hydro-Electric Project (100 MW)

Sarabai (Bhuntar), Distt.-Kullu, (HP)-175125 Website: www.hppcl.inE-mail:smlarji.e@gmail.comFax &Phone No: 01902 265191

The vendors/suppliers/contractors which are blacklisted by our organization (HPPCL) or any 18. other PSUs/Govt. Organization are not eligible to bid in this tender and even order issued to such bidder may get cancelled. 19.

HPPCL reserve the right to terminate the contract at any time without any prior notice. 20.

In case of any dispute between HPPCL & Contractor/Service provider, the jurisdiction of court shall be at Kullu, (HP) only. 21.

While generating the invoice for payment purposes, HPPCL GSTN No. i.e.

02AABCH8615G1ZX be mentioned appropriately.

Engineer-in-Charge for rewinding of motors job work/ Billing Address:- Sr. Manager (P&C), 22. Sainj HEP, HPPCL, Sarabai (Bhuntar), Distt-Kullu, (HP)-175125 OR or his authorized

Senior Manager

(Procurement & Contracts), Room No.: #301, Top Floor, Sainj HEP, office complex, HPPCL, Sarabai (Bhuntar), Distt-Kullu, (HP)-175125

No. HPPCL/SHEP/SM(P&C)/NIQ-CaseFile/2025-26 /16-2/ Dated: /0/06/2025

Copy of above is forwarded to the following for information and necessary action please:

The Addl. General Manager (Elect.)-cum-HoP, Sainj HEP, HPPCL, Sarabai (Bhuntar), Distt-1.

The Sr. Manager (IT), Himfed Building, HPPCL, Near BCS, New Shimla for kind 2. information and it is requested to upload NIQ on the official website of HPPCL.

The Sr. Manager (O&M), Sainj HEP, HPPCL, Matla, Distt-Kullu, (HP). 3.

The Finance and Accounts wing, Sainj HEP, HPPCL, Sarabai (Bhuntar), Distt-Kullu, (HP). 4.

5. Notice board of this office.

Case file. 6.

Regd. office: Himfed Building, Near BCS, New Shimla, HP-171009.

Pg 23 of 23